



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/09/2026

Shift: C

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment         | Problem                                                      | Action                  | From     | To       | Remarks |
|-------|------|-------------------|--------------------------------------------------------------|-------------------------|----------|----------|---------|
| 1     | OHP  | CO 34a            | ZSS acting due to belt slipping                              | Informed to oprn        | 03:30:00 | 03:45:00 |         |
| 2     | OHP  | TBS on CO 21 LT   | M1 trip                                                      | Reset                   | 03:10:00 | 03:30:00 |         |
| 3     | OHP  | WBR on co 26      | Incomer tripped in lbds 5 due to Heavy moisture in I/O panel | Hot blowing done        | 22:00:00 | 01:00:00 |         |
| 4     | OHP  | WBR on co 26 b/c  | PLC Power recycled                                           | Then OK                 | 03:30:00 | 04:00:00 |         |
| 5     | OHP  | CO 7A ZSS         | Probe Damaged                                                | Replaced                | 03:50:00 | 04:30:00 |         |
| 6     | OHP  | WBR on CO 25 LT   | M3 trip Due to Track Jamming                                 | Informed to Oprn        | 01:30:00 | 02:00:00 |         |
| 7     | OHP  | OP 5, 6           | Power TRipped                                                | Made it on              | 23:00:00 | 00:30:00 | 3 times |
| 8     | CHP  | CC 29             | Control MCB tripping due to Earth fault in C/S               | RL 1 to RL 2 loop given | 03:30:00 | 04:00:00 |         |
| 9     | CHP  | Scr 7 on CC 40 LT | Drive Trip                                                   | Reset                   | 22:30:00 | 22:40:00 |         |
| 10    | CHP  | SCR 1 ON CC 31    | B/C ZSS                                                      | Bypassed                | 02:00:00 | 02:15:00 |         |
| 11    | CHP  | SCR 5 On CC 32    | One HT Fuse blown                                            | Checking under Progress | 01:00:00 | 06:00:00 |         |
| 12    | CHP  | SCR 8 on CC 112   | VCB trip on Machine                                          | Made it on              | 05:00:00 | 06:00:00 |         |
| 13    | CHP  | CC 52 C/S         | Probe got cut                                                | Rejoined                | 01:10:00 | 01:20:00 |         |
| 14    | CHP  | RG1               | CTMF fault                                                   | Reset                   | 23:05:00 | 23:15:00 |         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/09/2026

Incharge(s): G Eswara Rao

Shift: C

| Sl No | Area | Equipment | Problem         | Action     | From     | To       | Remarks |
|-------|------|-----------|-----------------|------------|----------|----------|---------|
| 15    | WT   | OP 9      | Power Tripped   | Made it on | 03:00:00 | 03:10:00 |         |
| 16    | WT   | OP2       | Breaker Tripped | Made it on | 23:30:00 | 23:40:00 |         |