



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/08/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-26	REPORTED LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED THAN OK	01:25:00	01:45:00	
2	OHP	TBS ON CO-20	REPORTED LT NOT TAKING PLACE FOUND PCRD O/T ACTED AND ALSO CABLE OVER LAPPING INFORMED TO MECH	O/T RELEASED AND CABLE PROPER LAYING WAS DONE WITH MECHANICAL	22:30:00	22:40:00	
3	OHP	WOBR ON CO-29	REPORTED C/S NOT WORKING FOUND NO PROBLEM	C/S NOW OK	03:40:00	03:50:00	
4	CHP	CC-52	MPD TRIP (FEEDING CONVEYOR STOP)	RESET DONE	05:40:00	05:45:00	
5	WT	op-7	REPORTED NOT MOVE FOUND DRIVE-4 TRIP	RESET DONE	23:50:00	00:00:00	