



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 15/05/2026

Area: WT

Equipment	Job
LC 1 and 2B /T2	Charged H T and LT side after D N W clearence
OT 4	proximate sensor replaced for intial indication
OP 4	Panel and Motor side ppm including core cleaning done
MIS	Material shifted to op 5