# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 29/10/2026

Shift: A

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | WBR on CO 6a | Break 2 OLR fault | Disconnected | 06:35:00 | 06:55:00 | |
| 2 | OHP | WBR on CO 6a | B/W Solenoid valve stuck | Made it free | 12:35:00 | 12:55:00 | |
| 3 | OHP | BRC on CO 32 LT | Drive 2 (CRMP) trip | Reset | 13:35:00 | 13:45:00 | |
| 4 | OHP | TBS on CO 24 LT | Break tight | Informed to mech | 08:30:00 | 08:45:00 | |
| 5 | CHP | SCr 7 on CC 40 | B/C OLR acted | Reset | 09:25:00 | 09:35:00 | |
| 6 | CHP | CC 131 | Panel out going to Motor Tb cable Y phase Earth Fault | Checking under progress | 13:20:00 | 14:00:00 | |
| 7 | WT | CO 3 | OLR acted | Reset | 06:00:00 | 06:30:00 | 2 times |