



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/05/2026

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26 WBR	LT NOT WORKING PCRD OT ACTED	RELEASED	17:45:00	17:55:00	
2	OHP	CO-20 TBS	CHUT SENSOR NOT HEALTHY	WAS NOT FIXED PROPERLY ... FIXED	17:30:00	18:00:00	
3	OHP	RCO-1A	NOT STARTING IN REV	NO ELECTRICAL PROBLEM FOUND	17:20:00	17:40:00	
4	CHP	CC-131	TRIPPED ON OLR	RESET DONE	15:40:00	15:45:00	
5	CHP	CC-36 S-1	LT M1 MPCB TRIPPED	RESET DONE	19:10:00	19:20:00	
6	WT	OT-3	D2 TRIPPED ON ENCODER FAULT	RESET DONE	15:00:00	15:10:00	