



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/05/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done	07:00:00	07:10:00	
2	OHP	BRC on CO-8A	PCRD cable lying on ground	Cable winding done	10:50:00	11:10:00	
3	CHP	CC-105 SCR-10	B/W not running	MPD tripped.Made on	08:50:00	08:55:00	
4	CHP	CC-125	Reported tripped	OLR acted.Reset done	08:50:00	08:55:00	
5	IOSA	TBS	B/C stopping	ZSS cage stuck with stone.Removed and tested okay	07:45:00	07:55:00	