



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	16:00:00	21:00:00	2TIMES
2	OHP	CO 25	OLR ACTED	RESET	20:45:00	20:55:00	
3	OHP	WBR ON 6A NO DRIVE RUNNING	EMERGENCY STOP NEAR HYDRAULIC MOTOR ACTED	RELEASED	15:25:00	15:35:00	
4	CHP	SCR 2 ON CO 33	LT DRUM SENSOR ACTED	RESET	19:00:00	19:15:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	18:00:00	20:00:00	2 TIMES
6	CHP	CC 131	OLR ACTED	RESET	20:15:00	20:20:00	