



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 22/08/2026

Area: CHP

| Equipment                  | Job                                                         |
|----------------------------|-------------------------------------------------------------|
| CC 28                      | Motor replaced and trail run was taken                      |
| CC 52 D/E Hoist            | Panel cable dressing done                                   |
| LC 13,19                   | Inside scrap material removed                               |
| RG 1,2,3                   | Motor fan cover fixing bolts tightness checked              |
| SCR 6                      | Boom conveyor motor fan cover fixed properly                |
| CC 3/36/37 T/E, CC 222/223 | Lighting improved                                           |
| CC 31                      | Removed motor coupling removed and sent to ERS              |
| CC 31                      | Motor replaced with brand new motor and trail run was taken |