वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 20/10/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted	reset done	03:10:00	03:15:00	
2	OHP	wobr on co 29	b/w not running,olr acted	reset	04:15:00	04:35:00	
3	OHP	TBS on CO 20	lighting not working in operator cabin,mcb tripped	made it on	23:00:00	23:10:00	
4	OHP	CO 25	olr acted	reset	05:40:00	05:50:00	
5	CHP	CC 130	tis mcb tripped	reset	04:05:00	04:15:00	
6	IOSA	OC 25 A	tripped due to OL	reset	04:20:00	04:30:00	