



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/05/2026

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment        | Problem                                                    | Action                | From                             | To                               | Remarks |
|-------|------|------------------|------------------------------------------------------------|-----------------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | CO-41A           | REPORTED BRS ACTING FREQUENTLY<br>FOUND BELT PIECE HANGING | INFORMED TO OPERATION | 09:20:00                         | 09:30:00                         |         |
| 2     | CHP  | CC-52            | MPD TRIP                                                   | RESET DONE            | 08:20:00                         | 08:25:00                         |         |
| 3     | CHP  | CC-37<br>SCR-3   | REPORTED B/C NOT RUNNING 30DEGREE<br>LIMIT ACTED           | SLEW DONE THAN OK     | 06:30:00                         | 06:40:00                         |         |
| 4     | CHP  | CC-37<br>SCR-3   | LT NOT TAKING PLACE M-3 TRIP                               | RESET DONE            | 06:30:00                         | 06:40:00                         |         |
| 5     | CHP  | CC-31<br>SCR-1   | LUFF NOT WORKING OLR ACTED                                 | RESET DONE            | 07:05:00                         | 07:15:00                         |         |
| 6     | CHP  | CC-125           | MPD TRIP                                                   | RESET DONE            | 12:30:00                         | 12:35:00                         |         |
| 7     | WT   | OT-3,DRIV<br>E-2 | SANTURATION-7 FAULT TRIP (3TIMES)                          | RESET DONE            | 08:00:00<br>10:45:00<br>11:10:00 | 08:05:00<br>10:50:00<br>11:15:00 |         |