



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 29	B/W TRIPPING IMMEDIATELY	MOTOR MEGERED VALUES OK	03:30:00	06:00:00	TO BE CHECKED
2	CHP	CC 58	OLR ACTED	RESET	22:30:00	22:45:00	
3	CHP	CC 54	OLR ACTED	RESET	23:45:00	23:50:00	
4	CHP	CC 54	FEEDING CONV OLR ACTED	RESET	01:00:00	02:10:00	4 TIMES