



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/06/2026

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment     | Problem                     | Action                    | From     | To       | Remarks |
|-------|------|---------------|-----------------------------|---------------------------|----------|----------|---------|
| 1     | OHP  | TBS ON CO-5A  | LT M2 TRIPPED               | RESET DONE                | 14:20:00 | 14:30:00 |         |
| 2     | OHP  | CO-34         | BRS NOT HEALTHY             | FUSE PROBLEM ... REPLACED | 17:00:00 | 17:30:00 |         |
| 3     | OHP  | CO-26         | TRIPPED ON OLR              | RESET DONE                | 18:30:00 | 18:35:00 |         |
| 4     | OHP  | WBR ON CO-29  | LUFF TRIPPED ON OLR         | RESET DONE                | 18:45:00 | 19:00:00 |         |
| 5     | OHP  | BRC ON CO-28  | BC TRIPPED ON OL            | RESET DONE                | 19:55:00 | 20:10:00 |         |
| 6     | CHP  | CC-51         | MPD TRIPPED                 | RESET DONE                | 16:40:00 | 16:45:00 |         |
| 7     | CHP  | CC-52         | NOT HEALTHY ... EM PB ACTED | RELEASED                  | 16:20:00 | 16:30:00 |         |
| 8     | CHP  | cc-40         | luff down limit bypass      | as per operation request  | 16:05:00 | 16:15:00 |         |
| 9     | CHP  | cc-106 scr -9 | ht power tripping in lc-2   | checking going on         | 21:00:00 | 22:00:00 |         |