



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/09/2026

Incharge(s): Nagendra Midde,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 20	Left B/C OLR acted	Reset	16:05:00	16:16:00	
2	OHP	BRC on CO 30	B/C OLR acted	Reset	17:35:00	17:45:00	
3	OHP	CO 26	OLR acted	Reset	18:15:00	18:25:00	
4	OHP	CO 56	OLR malfunctioning	Bypassed	17:30:00	17:45:00	
5	OHP	CR1a	I/O rack supply tripped	Made it on	21:30:00	21:45:00	
6	OHP	CO 11 ZSS	Probe Check nut Loose	Tightened	16:30:00	16:45:00	
7	CHP	R1 on CC 39	Common High Fuse blown	Replaced	19:30:00	19:45:00	
8	CHP	S 2 on CC 35	B/C OLR acted	Reset	20:45:00	20:55:00	
9	CHP	CC 52	Feeding Conv OLR acted	Reset	15:30:00	18:30:00	2 times
10	CHP	CC 131	OLR acted	Reset	18:30:00	18:40:00	
11	CHP	CC 26 F/G	OLR acted	Reset	14:50:00	15:00:00	