RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/10/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 8A	LT not working ,drive tripped	reset	17:00:00	17:10:00	
2	OHP	BRC on CO 32	LT not working,PCRD OT acted	OT released	20:00:00	20:05:00	operator went to 31 m/c
3	OHP	CO 48	OLR acted	reset	17:00:00	17:10:00	
4	OHP	CC 106 SCR8	LT not working,control supply mcb tripped	made it on	18:10:00	18:30:00	
5	OHP	CC 37 SCR3	slew not working,jamming was there	informed operation	19:15:00	19:30:00	
6	CHP	CC 31 SCR1	b/c not running,chute jamming,iron plate stucked,CJD cable got cut,ZSS fuse blown	operation cleaned the jamming,cjd wire jointed,fuse replaced	18:30:00	19:10:00	
7	CHP	CC 32 SCR5	LT not working,OT acted	OT released	19:30:00	19:45:00	
8	CHP	SCR1 CC 31	bc not running,ZSS problem,module problem	bypass and refer to C shift	20:55:00	21:10:00	module to be replaced
9	CHP	CC 38 SCR6	b/c not running,zss cage coal stucked	cage made free	20:55:00	21:10:00	
10	CHP	CC 51	MPD tripped on OLR	reset	16:10:00	16:15:00	