



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/06/2026

Area: CHP

Equipment	Job
CC 9 side	Total 32 fixtures replaced and 22 nos 70W fixtures removed
CC 114,115	PPM was done
SCR 5,6,9,10,S 2	Safety switches inspection done
CC 31	Damaged contactor kit replaced
CM 18	Room cleaning done