RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 12/11/2026

Area: CHP

Equipment	Job
LC 14	De watering pump replaced and de watered
CC 56	BS kept in ckt
SCR 5,10	Instrumentation sensors maintenance done
Cleaning done	Coal complex,CC 104 HT I/C surrounding,LC 19,CM 24,27
CC 25,32,SCR 5	PPM done