



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 28	BC not running, olr acted	reset	14:00:00	14:10:00	
2	OHP	co 26	olr acted	reset	16:50:00	17:00:00	
3	OHP	co 25	olr acted	reset	18:40:00	18:50:00	
4	CHP	CC 131	olr acted	reset	21:15:00	21:20:00	
5	CHP	CC 36 STK1	LT not working, m1 tripped on olr	reset	17:05:00	17:15:00	
6	CHP	CC 107	mpd tripped	reset	21:35:00	21:40:00	