



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/09/2026

Shift: C

Incharge(s): Nagendra Midde, G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-25	olr acted (6times)	reset done	00:50:00	05:30:00	
2	OHP	CO-26	TRIPPED ON OLR	RESET DONE	03:00:00	03:10:00	
3	OHP	WOBR ON CO6A	REPORTED SLEW NOT STOPPING FOUND STOP BUTTON STUCK UP	RELEASED THAN OK	00:30:00	00:40:00	
4	WT	OP-2	REPORTED NOT MOVE FOUND DRIVE-1 TRIP	RESET DONE	04:50:00	05:05:00	
5	WT	OP-2	REPORTED NOT MOVE FOUND M-1 TRIP AND SMOKE OBSERVED FROM DRIVE-4	DRIVE-1 RESET AND DRIVE-4 DISCONNECTED	05:30:00	05:45:00	