



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/05/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done	17:40:00	17:50:00	
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	19:45:00	20:00:00	
3	OHP	BRC on Co-28	B/W-2 not running	Motor running.Gearbox problem	19:00:00	19:20:00	Informed to mechanical
4	OHP	RSCO-10A	Reported CJD not working	Fuse blown.Replaced and tested okay	19:45:00	20:05:00	
5	OHP	TT-4 CJD	Not healthy	CS glass fuse TB loose.Tightened	20:15:00	20:25:00	
6	CHP	CC-18	ZSS acting	Belt slipping	17:05:00	17:15:00	Informed to mechanical