# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 26/10/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | BRc on CO 32 | ACB in off condition | Made it on | 15:20:00 | 15:35:00 | |
| 2 | OHP | BRC on CO 8a | Lt M1 Trip | Reset | 18:40:00 | 18:55:00 | One Bhogi Derailed |
| 3 | OHP | CC 25 | OLR acted | Reset | 19:10:00 | 19:20:00 | |
| 4 | OHP | BRC on CO 30 B/C | OLR acted | Reset | 19:40:00 | 19:50:00 | |
| 5 | OHP | WBR on CO 29 B/W | OLR acted | Reset | 20:55:00 | 21:10:00 | |
| 6 | CHP | CC 47 | Selector switch in local mode | Changed to Remote | 20:05:00 | 20:15:00 | |
| 7 | CHP | CC 58 | OLR acted | Reset | 17:10:00 | 17:25:00 | |
| 8 | CHP | CC 51 | Feeding conv olr acted | Reset | 21:10:00 | 21:15:00 | |
| 9 | CHP | S3 on CC112 | Old HT Joint Failure | After DNW clearance Charged | 15:00:00 | 19:00:00 | |