



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/06/2026

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	ALL FIELD DEVICES AND MOTOR TBS COVERED WITH TARPAULIN SHEET.
OC-33A	LIGHTING CIRCUIT DEFECTS RECTIFIED AND SUFFICIENT LIGHTING PROVIDED.
OC-31A	LIGHTING CIRCUIT DEFECTS RECTIFIED AND SUFFICIENT LIGHTING ARRANGED.
OC-2A	SUFFICIENT LIGHTING ARRANGED
OC-3A	PPM DONE ON MOTOR