



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/05/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	OP3	D3 TRIP	RESET	09:20:00	09:35:00	
2	OHP	CO 15 HEALTHY STOPPING	POSITION SENSOR STRIKER NOT PLACED PROPERLY	PROPERLY PLACED THEN OK	12:30:00	13:00:00	
3	OHP	CO 70 RED	EMERGENCY STOP PB ACTED	RELEASED	09:20:00	09:30:00	