



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/08/2026

Incharge(s): G Eswara Rao

Shift: A

| Sl No | Area | Equipment       | Problem                                      | Action                   | From     | To       | Remarks |
|-------|------|-----------------|----------------------------------------------|--------------------------|----------|----------|---------|
| 1     | OHP  | WOBR ON CO 6A   | BW AND SLEW ARE NOT TAKING PLACE/CP 2 ACTING | INFORM TO OPE. AND MECH. | 10:50:00 | 11:10:00 |         |
| 2     | OHP  | co 26           | tripped on olr                               | reset done               | 08:55:00 | 09:05:00 |         |
| 3     | CHP  | CC 203          | REPORTED RED/CONTROL MCB TRIPPED             | MCB MADE ON              | 10:30:00 | 10:40:00 |         |
| 4     | CHP  | CC 28           | TRIPPED ON OLR                               | RESET DONE               | 12:30:00 | 12:40:00 |         |
| 5     | CHP  | CC 52           | MPD TRIPPED ON OLR                           | RESET DONE               | 10:45:00 | 10:55:00 |         |
| 6     | CHP  | scr 1 on cc31   | drive tripped on olr                         | reset done               | 09:10:00 | 09:25:00 |         |
| 7     | CHP  | R1 ON CC        | BC NOT WORKING                               | FAULT RESET DONE         | 10:25:00 | 10:45:00 |         |
| 8     | CHP  | SCR 5 ON CC 39  | L NOT TAKING PLACE/PCRD TENSION ACTED        | RELEASED                 | 11:10:00 | 11:25:00 |         |
| 9     | CHP  | SCR 9 ON CC 104 | LT NOT TAKING PLACE/M6 CONTROL WIRES LOOSE   | CONTROL WIRES TIGHTEND   | 11:20:00 | 11:35:00 |         |
| 10    | CHP  | CC 31           | TRIPPED ON OLR                               | RESET DONE               | 12:15:00 | 12:30:00 |         |
| 11    | CHP  | SCR 1 ON CC31   | SLEW NOT TAKING PLACE/30DEGREE LIMIT ACTED   | RELEASED                 | 13:10:00 | 13:25:00 |         |
| 12    | CHP  | R1 ON CC39      | BC STOPPING ON ZSS/CAGE STUCKUP              | CAGE MADE FREE           | 10:25:00 | 10:45:00 |         |