



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/08/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RBF-1A	DRIVE TRIP	RESET DONE	00:50:00	01:00:00	
2	OHP	CO-50	OLR ACTED	RESET DONE	01:15:00	01:30:00	
3	OHP	CO-25	OLR ACTED (4TIMES)	RESET DONE	01:30:00	03:30:00	
4	OHP	WOBR ON CO-26	REPORTED B/C NOT RUNNING FOUND ZSS CAGE STUCK UP DUE TO BEARING PROBLEM	ZSS CAGE REPLACED WITH NEW ONE THAN OK	03:00:00	03:30:00	
5	OHP	TBS ON CO-5A	LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED THAN OK	04:30:00	04:45:00	
6	CHP	CC-33 SCR-2	REPORTED SLEW NOT WORKING DRIVE TRIP	RESET DONE	00:00:00	00:15:00	