



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/06/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment              | Problem                           | Action                     | From                 | To                   | Remarks |
|-------|------|------------------------|-----------------------------------|----------------------------|----------------------|----------------------|---------|
| 1     | OHP  | BRC ON CO 28           | B/C OLR ACTED                     | RESET                      | 19:00:00<br>20:50:00 | 19:15:00<br>21:05:00 |         |
| 2     | OHP  | BRC ON CO 33M<br>B/W 2 | INTERLOCK PANEL ALL TBS TIGHTENED | THEN OK                    | 20:45:00             | 21:30:00             |         |
| 3     | CHP  | CC 45                  | CONTROL MCB PROBLEM               | REPLACED                   | 20:15:00             | 20:40:00             |         |
| 4     | CHP  | CC 125                 | OLR ACTED                         | RESET                      | 20:20:00             | 20:25:00             |         |
| 5     | CHP  | CC 51                  | FEEDING CONV OLR ACTED            | RESET                      | 17:50:00             | 21:40:00             | 8 TIMES |
| 6     | CHP  | CC 113A<br>F/G         | OLR ACTED                         | RESET                      | 14:35:00             | 14:45:00             |         |
| 7     | WT   | OT 3                   | TRIPPING FREQUENTLY MECH PROBLEM  | RESET AND INFORMED TO MECH | 19:00:00             | 19:30:00             |         |