



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/08/2026

Area: CHP

| Equipment | Job                                                                                                                |
|-----------|--------------------------------------------------------------------------------------------------------------------|
| CC 130    | Motor replaced,alignment done and direction tested.Empty motor currents and vibration readings noted               |
| CC 27A    | Motor replaced and trail run was taken.Current and vibration readings noted                                        |
| R 1       | Machine lighting improved after providing 12 nos 35W LED fixtures                                                  |
| SCR 8     | Position and stacking angle limits provide with magnetic switches in place of rotary switch,cables laid and tested |
| CC 45     | PPM was done                                                                                                       |
| LC 2      | Rooms cleaning done                                                                                                |