



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 76 R	OLR ACTED	RESET	14:30:00	14:45:00	
2	OHP	CO 26	OLR ACTED	RESET	15:20:00	20:20:00	2 TIMES
3	OHP	WBR ON CO 25	SLEW DRIVE TRIPPED	RESET	16:10:00	16:30:00	
4	OHP	WBR ON CO 25 LT	M2 BREAK PROBLEM	INFORMED TO MECH	18:15:00	18:30:00	
5	OHP	TBS ON CO 21 LT	PCRD O/T ACTED	RELEASED	20:30:00	20:50:00	
6	OHP	CO 6 BRS	FUSE BLOWN	REPLACED	15:50:00	16:05:00	
7	CHP	CC 54	OLR ACTED	RESET	19:05:00	19:10:00	
8	WT	OT3	D2 TRIP	RESET	15:15:00	15:20:00	
9	WT	CP 3	COMMUNICATION PROBLEM	POWER RECYCLED THEN OK	15:30:00	15:40:00	
10	WT	CT 1	D1 TRIP	RESET	15:00:00	15:10:00	
11	WT	CP 2	TRIP IN LC 10A	MADE IT ON	20:40:00	20:50:00	