



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/08/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	18:20:00	18:30:00	
2	OHP	CO 5A	brs acted due to dust	sensor cleaned than ok	20:10:00	20:20:00	
3	CHP	CC 111 and 112	yard conveyor stoped due to ACB tripped in CM36	made it on	18:40:00	18:50:00	
4	CHP	CC 52	mpd acted	reset	15:15:00	15:20:00	2 times
5	CHP	CC 54	olr acted	reset	15:40:00	15:50:00	
6	CHP	CM 36	main ACB tripped	made it on	18:50:00	19:00:00	