



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/08/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	TRIPPED ON OLR 4 TIMES	RESET DONE	23:00:00	01:42:00	
2	OHP	CO-10A	TRIPPED ON OLR	RESET DONE	01:50:00	02:00:00	
3	OHP	CO-26 WBR	SLEW NOT WORKING RIGHT SIDE	LIMIT STUCK ... MADE FREE	03:40:00	04:00:00	
4	CHP	CC-15	TRIPPED ON OLR	RESET DONE	02:00:00	02:10:00	
5	CHP	CC-36 S1	LT M1 TRIPPED	RESET DONE	22:40:00	22:50:00	
6	IOSA	OC-14A	MPD TRIPPED	RESET DONE	01:15:00	01:30:00	