



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/09/2026

Shift: C

Incharge(s): Nagendra Midde,Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted	Reset	23:00:00	04:55:00	2 Times
2	OHP	CO 26	OLR acted	Reset	01:10:00	04:50:00	2 Times
3	OHP	VF 10	OLR acted	Reset	23:35:00	23:45:00	
4	OHP	WBR on co 29 B/w	OLR acted	Reset	01:55:00	02:05:00	
5	OHP	WBR on CO 29 LT	M4 trip	Reset	05:50:00	06:00:00	
6	OHP	TBS on co 19 Lt	Forward Pb not working properly	Pb Cleaned properly then ok	00:30:00	01:00:00	
7	CHP	CC 130 RED	Emergency stop acted	Reset	23:00:00	23:15:00	
8	CHP	SCR 4 on CC 111	PCRD o/t acted	Released	05:30:00	05:45:00	
9	CHP	CC 28 t/t	MPCB Trip	Made it on	22:30:00	22:45:00	
10	WT	OP2	Breaker Trip	Made it on	05:45:00	06:00:00	
11	IOSA	BRC on OC 15 a	Emergency stop PB acted Near BW 1	Released	01:15:00	01:30:00	