RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 13/11/2026

Area: OHP

Equipment	Job
wobr-1 on 26 and wobr-3 on 25.	LT speeds regulated as per mechanical requirement,
Misc	Light Fittings preparation is done.
crusher 3a	Lubrication pump, both ends coupling is replaced and trail run is taken.
co-45 pullchord,	cable is laid, switches fixed to side columns, to be terminated and taken in circuit.
tbs-6 on co-7a	Left Boom Conveyor DMPR failed, replaced with spare one and tested.
wobr-3 on co-25	Isolator panel was fixed back and welded into position. PPM is done.
rco-2a brs	sensors fixed properly in place, alignment done , local trail run is taken and restored brs in circuit.