वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 12/11/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | CO 26 | olr acted | reset | 22:05:00 | 22:10:00 | 2 times |
| 2 | OHP | CO 29 | olr acted | reset | 22:40:00 | 22:45:00 | |
| 3 | OHP | BRC on CO 31 | b/c not running,olr acted | reset | 02:15:00 | 02:25:00 | |
| 4 | OHP | TBS on CO 22 | LT not working,OT acted | OT released | 05:15:00 | 05:30:00 | |
| 5 | OHP | cc 107 | stopped in ZSS,conveyor overloaded | informed operation | 05:50:00 | 05:55:00 | |
| 6 | CHP | CC 35 S2 | LT not working,M1 tripped | reset | 02:50:00 | 03:00:00 | |
| 7 | CHP | cc 131 | mpd acted | reset | 03:15:00 | 03:20:00 | |
| 8 | CHP | CC 201 | olr acted | reset | 23:50:00 | 23:55:00 | |
| 9 | CHP | CC 14 | olr acted | reset | 00:05:00 | 00:10:00 | |
| 10 | IOSA | L and T wobr | bc not running,pc acted | Pc released | 22:45:00 | 23:00:00 | |