



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/06/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC 58	OLR ACTED	RESET	07:40:00	07:55:00	
2	OHP	TT4 ON BP1	POSITION SENSOR ON BP1 CABLE CUT	REJOINED	08:10:00	08:30:00	
3	OHP	CO 29	OLR ACTED	RESET	09:30:00	09:40:00	
4	OHP	CO 25	OLR ACTED	RESET	07:30:00	07:40:00	
5	OHP	BRC ON CO 32 B/W 2	GUIDE ROLLER STUCK UP	INFORMED TO MECH	07:05:00	07:15:00	
6	OHP	CR 2A STOPPING ON ZSS	ZSS PROBE CHECK NUT LOOSE	TIGHTENED	12:05:00	12:20:00	
7	OHP	BRC ON CO 32 B/C STOPPING FREQUENTLY	CHP SIDE CHUTE SENSOR MALFUNCTIONING	BYPASSED	13:30:00	13:50:00	
8	CHP	SCR 7 ON CC 40 B/C	SLEW 30 DEGREE LIMIT ACTED	RELEASED	11:30:00	11:45:00	
9	WT	OT3	D2 TRIP	RESET	06:10:00	06:15:00	