



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/09/2026

Incharge(s): Nagendra Midde, K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED	RESET DONE	01:20:00	01:25:00	
2	CHP	RG-1	TRIPPED ON OLR	RESET DONE	23:40:00	00:00:00	
3	CHP	CC-22	OLR ACTED	RESET DONE	04:55:00	05:05:00	
4	CHP	CC-37	TRIPPED ON OLR CHECKED AND FOUND MOTOR BURNT	INFORMED TO A SHIFT	05:30:00	06:00:00	