



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	16:45:00 18:20:00	16:55:00 18:25:00	
2	OHP	WBR ON CO 6A B/W	OIL LEVEL LOW	INFORMED TO MECH	15:15:00	15:25:00	
3	OHP	CO 29	OLR ACTED	RESET	16:00:00	21:15:00	3 TIMES
4	OHP	CO 13 CD	MPCB TRIPPED	RESET	17:30:00	17:40:00	
5	CHP	CC 107	OLR ACTED	RESET	17:15:00	17:20:00	