



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED	RESET	01:00:00	01:10:00	
2	OHP	CO 26	OLR ACTED	RESET	05:40:00	05:50:00	
3	CHP	SCR 1 ON CC 31	LUFF OLR ACTED	RESET	02:45:00	02:55:00	
4	CHP	SCR 7 ON CC 39 B/W	CHANEL GOT STUCK	INFORMED TO MECH	03:50:00	04:00:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	03:55:00	04:00:00	
6	CHP	CC 131	OLR ACTED	RESET	03:55:00	04:00:00	