



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/08/2026

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	SCR 6	Slew problem	Material jamming cleared	12:50:00	13:00:00	
2	CHP	CC 54	OLR acted	Reset	10:20:00	10:30:00	
3	WT	OP-7	FWD not moving	Tipper clamp limits switch MCB tripped in PLC panel,Reset	11:01:00	11:10:00	