RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 23/10/2026

Area: CHP

Equipment	Job
SCR 7,8,9,10.R 1	Machine inspection done for safety switches and HT coupler heaters
SCR 2,3,4,5	Instrumentation sensors maintenance was done
CC 42,111,SCR 4	PPM was done
RG 1,VS 1,VF 1	PPM was done
I/C 5 (CC 38)	Bus bar maintenance done
CM 17	Bus bar maintenance was done
CM 6	Original ACB placed and charged
CC 9	Panel out going B phase damaged Cu bus and lugs replaced ,terminate and trail run was taken