RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 15/10/2026

Area: CHP

Equipment	Job
CC 53	4 nos PC switches wiring completed and kept in ckt
CC 13,17,24,51A	PPM done
CM 19	Room cleaning done
SCR 8	LT control earth fault isolated and kept end limit in ckt
SCR 1	Boom position switch replaced and kept in ckt
S 3	Shifted from CC 112 to repair bay
CC 38,SCR 6	PPM was done