



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/05/2026

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment                    | Problem                                        | Action                  | From     | To       | Remarks |
|-------|------|------------------------------|------------------------------------------------|-------------------------|----------|----------|---------|
| 1     | OHP  | OP3                          | D3 TRIP                                        | RESET                   | 09:20:00 | 09:35:00 |         |
| 2     | OHP  | CO 15<br>HEALTHY<br>STOPPING | POSITION SENSOR STRIKER NOT PLACED<br>PROPERLY | PROPERLY PLACED THEN OK | 12:30:00 | 13:00:00 |         |
| 3     | OHP  | CO 70 RED                    | EMERGENCY STOP PB ACTED                        | RELEASED                | 09:20:00 | 09:30:00 |         |