



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	06:55:00	07:05:00	
2	OHP	BRC on co 32	b/c not running, EM PB acted near cabin	emergency released	07:55:00	08:10:00	
3	CHP	CC 31 scr1	b/c not running in stacking mode, slew limit acted	slew done than ok	06:55:00	07:05:00	
4	CHP	cc 31	mpd tripped	reset	10:45:00	10:50:00	
5	CHP	cc 201	olr acted	reset	08:45:00	08:55:00	
6	CHP	cc 131	olr acted	reset	10:00:00	10:10:00	