



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 15/05/2026

Area: CHP

| Equipment              | Job                                             |
|------------------------|-------------------------------------------------|
| CC 25,27,27A and TTs   | PPM was done                                    |
| CC 7 and CC 9          | Sump pump maintenance done                      |
| CM 28                  | Burnt cables removed and cable dressing done    |
| CC 219                 | Mechanical BRS unit installed ,wiring completed |
| All yard HT couplers   | Heating element inspected,found all are working |
| JH C 19,212,CC 126D/E  | Hoist panels maintenance done                   |
| CC 31,38,48,49,SCR 1,5 | Running inspection done                         |