



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/09/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11	ZSS ACTING/CAGE STUCKUP	CAGE REPLACED	18:10:00	18:30:00	
2	OHP	TBS ON CO 20	LT NOT TAKING PLACE/TENSION ACTED DUE TO PCRD GUIDE PROBLEM	INFORM TO OPERATION AND MECH.	20:00:00	20:10:00	
3	CHP	CC 26	FLAP GATE TRIPPED ON OLR	RESET DONE	15:55:00	16:05:00	
4	CHP	CC 201	TRIPPED ON OLR	RESET DONE	18:05:00	18:10:00	
5	CHP	SCR 1ON CC31	SLEW NOT TAKING PLACE/30 DEGREE LIMIT ACTED	LIMIT REASED	14:30:00	14:45:00	
6	CHP	SCR 7 ON CC40	LUFFING NOT WORKING/DOWN LIMIT ACTED	LIMIT BYPASSED AT I/O RACK FOR OPERATION	16:00:00	16:10:00	
7	CHP	SCR 3 ON CC36	LUFFING NOT WORKING/STOP PB FEED BACK NOT GETTING	USED SPARE CORE	16:15:00	16:35:00	
8	CHP	SCR 9 ONCC 104	NO DRIVES RUNNING/ACB TRIPPED	ACB MADE ON	18:40:00	18:50:00	
9	CHP	CC 52	MPD TRIPPED ON OLR/5 TIMES	RESET DONE	15:30:00	18:00:00	FEEDING C ONV.STOP ED
10	CHP	CC54	TRIPPED ON OLR	RESET DONE	16:35:00	16:40:00	
11	CHP	TT ON CC 53	LT NOT TAKING PLACE/TRIPPED ON OLR	RESET DONE	19:40:00	19:50:00	
12	WT	OT 2	F/R NOT TAKING PLACE/D1 TRIPPED ONPGF FAULT 3 TIMES	RESET DONE	17:30:00	20:00:00	
13	WT	OP 1	FORWARD NOT TAKING PLACE FROM PARKING ZONE	TEMPORARILY BYPASSED AND KEPT IN CKT	19:30:00	20:00:00	