RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/10/2026

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	Reset	11:15:00	13:45:00	2 times
2	OHP	CO 34a	Emergency stop Fuse blown	Replaced	08:40:00	08:55:00	
3	OHP	RSCO 10a	Selection in Remote	Kept in local	07:00:00	07:20:00	
4	OHP	CR2a	Lubrication pump mpcb trip	Made it on	12:55:00	13:05:00	
5	OHP	TBS on CO 22 pcrd not rotating	Wire got cut in Resistance Box	Properly Connected	10:00:00	12:00:00	No delay
6	OHP	CO 25	OLR acted	Reset	09:15:00	11:25:00	2 times
7	CHP	CC 125	OLR acted	Reset	10:10:00	10:15:00	
8	CHP	SCR 7 on CC 40	Lt Drive trip[	Reset	12:05:00	12:15:00	