



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/06/2026

Incharge(s): Nagendra Midde,Lal Singh

Shift: C

| Sl No | Area | Equipment        | Problem                   | Action       | From     | To       | Remarks |
|-------|------|------------------|---------------------------|--------------|----------|----------|---------|
| 1     | CHP  | CC 131           | OLR ACTED                 | RESET        | 02:00:00 | 02:05:00 |         |
| 2     | CHP  | CC 52            | FEEDING CONV OLR ACTED    | RESET        | 03:15:00 | 03:20:00 |         |
| 3     | CHP  | SCR 1 N<br>CC 31 | YARD INTERLOCK CAGE STUCK | MADE IT FREE | 23:30:00 | 23:50:00 |         |
| 4     | CHP  | CC 24            | OLR ACTED                 | RESET        | 22:30:00 | 22:40:00 |         |