



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO16	OLR ACTING FREQUENTLY DUE TO DECK SHEETS JAMMING	INFORMED OPRN TO CLEAN	17:30:00	20:30:00	4 TIMES
2	OHP	CO 26	OLR ACTED	RESET	15:45:00 20:45:00	15:55:00 21:00:00	
3	OHP	TBS ON CO 5A	LBC OLR ACTED	RESET	18:50:00	19:10:00	
4	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	14:20:00	21:25:00	2 TIMES
5	CHP	CC 54	OLR ACTED	RESET	15:35:00	15:40:00	
6	WT	OP5	D5 TRIPPED	RESET	18:30:00	18:50:00	
7	WT	OP1	D 5 TRIP	RESET	20:00:00	20:20:00	
8	WT	OT 3	D2 TRIPPED	RESET	21:00:00	21:05:00	
9	WT	CP 2	BREAKER TRIPPED IN LC 10A	MADE IT ON	19:30:00	19:40:00	