



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/08/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-10A	OLR ACTED	RESET DONE	05:05:00	05:10:00	
2	WT	OC-1A	REPORTED NOT HEALTHY FOUND K-2 RELAY LOOP LOOSE	TITLED THAN OK	04:50:00	05:05:00	