



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment    | Problem                           | Action      | From     | To       | Remarks |
|-------|------|--------------|-----------------------------------|-------------|----------|----------|---------|
| 1     | OHP  | co 26        | olr acted                         | reset       | 19:45:00 | 19:55:00 | 2 times |
| 2     | OHP  | co 25        | olr acted                         | reset       | 16:15:00 | 16:25:00 |         |
| 3     | OHP  | TBS on co 22 | all drive not working,control off | made it on  | 14:50:00 | 15:00:00 |         |
| 4     | CHP  | CC 213       | drive tripped                     | reset it    | 17:35:00 | 17:40:00 |         |
| 5     | CHP  | CC 213 scr 9 | slew not working,MCCB tripped     | made it on  | 18:55:00 | 19:05:00 | 2 times |
| 6     | CHP  | CC 32        | mpd tripped                       | made it on  | 20:40:00 | 20:45:00 |         |
| 7     | CHP  | CC 107       | olr acted                         | reset       | 21:25:00 | 21:30:00 |         |
| 8     | CHP  | CC 131       | tripped on olr                    | reset       | 19:40:00 | 19:45:00 | 2 times |
| 9     | WT   | OT 3         | D1 tripped in encoder fault       | reset       | 19:00:00 | 19:05:00 |         |
| 10    | IOSA | L and T WOBR | LT not working,OT acted           | OT released | 20:20:00 | 20:30:00 | 2 times |