



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/07/2026

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-6A	REPORTED SLEW NOT STOPPING FOUND E/STOP PROBLEM	RECTIFIED	22:50:00	23:00:00	
2	OHP	BRC ON CO-8A	REPORTED B/C NOT RUNNING OPERATOR CABIN SELECTOR IN LOCAL MODE	KEPT REMOTE THAN OK	02:20:00	02:30:00	
3	OHP	CO-25	OLR ACTED (3times)	RESET DONE	00:30:00	04:50:00	
4	OHP	RCO-6A	OLR ACTED	RESET DONE	23:05:00	23:10:00	
5	CHP	CC-29 TO CC-31	POSITION INDICATION NOT SHOW	PROPERLY PLACED THAN OK	22:40:00	22:50:00	
6	WT	OP-8	Reported not moving	Clamping de-clamping done and reset done in system and tested okay	22:30:00	22:45:00	