



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/08/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OVER CURRENT TRIP	RESET DONE	04:25:00	04:30:00	
2	CHP	CC-46	OLR ACTED	RESET DONE	22:40:00	22:50:00	
3	CHP	CC-104 SCR-9	REPORTED SLEW NOT WORKING FOUND AIR BLAST COOLER MPR TRIP	RESET DONE	02:45:00	02:55:00	
4	CHP	CC-104 SCR-9	REPORTED LT NOT TAKING PLACE FOUND M-2 OLR TRIP	RESET DONE	03:10:00	03:25:00	
5	WT	AF-4	REPORTED NOT HEALTHY FOUND CONTROL MCB TRIP	MADE ON	05:00:00	05:05:00	